

KARANDIKAR LABORATORIES PVT. LTD. BOISAR

Format: F#07 b.1 Rev 10

TYPE TEST REPORT

IS/IEC 60529:2001 (RA 2019)

Degrees of Protection Provided by Enclosures (IP Code)

Report No. : KLPL/BTG/25/01-123

ULR No. : TC411025000000136F

Discipline : Electrical Discipline

Group/Category : Environmental Test Facility

Sub-category : Ingress protection test

Date of issue : 17.05.2025

No. of pages : 06 PAGES + Annexure

Compiled by (+ signature)..... : Bhavesh Rawate

Designation: Testing Engineer

Approved by (+ signature)..... : Javed Shaikh

Designation: Dy.Laboratory Manager

Item Received On : 31.01.2025 in Good Condition

Test Completion Date : 06.02.2025

Client

Name : M/S. Metalmech Engineering

: Plot No. 4246, Road E, Dared, Phase-3, G.I.D.C.,
Jamnagar, Gujarat - 361001.

Test Specification

Standard : IS/IEC 60529:2001 (RA 2019)

Specified IP-Code : IP68

Equipment Under Test

Type of Test Object : MM AXL Series of Aluminium Enclosure,
Size: Ref. Page No.02 of This Report

Model : AXL Series

Serial No.. : NA



Manufacturer : M/s. Metalmech Engineering

Annexure :

Drawing No..... : MM-AXL-WE, Rev. No.00, Dated: 03.07.2024, (No. of Pages 02).

NOTE : 1) This refers only to the particular item(s) submitted for testing.

2) If necessary, this report shall be reproduced ONLY in full.



Possible test case verdicts:

Test case does not apply to the test object : N (Not Applicable)

Test object does meet the requirement..... : P (Pass)

Test item does not meet the requirement : F (Fail)

Test case has not been checked : _____

General remarks:

"(See remark #)" refers to a remark appended to the report.

"(See appended table)" refers to a table appended to the report.

Throughout this report a point is used as the decimal separator.

The test results presented in this report relate only to the object tested.

This test report shall not be reproduced except in full without the written approval of the testing Laboratory.

IP6X test conducted at Laboratory (Boisar).

IPX8 test conducted at Laboratory (Boisar).


Note: - MAJOR EQUIPMENTS USED

Tests	Required Instruments	Id. No.	Cal Due Date	Used Y/N
5X / 6X	Vacuum Meter	K&A 1108/1-17	07.02.2025	Y
	Rotameter	K&A 1346/23-4	24.12.2025	Y
	DTC with sensor	K&A 581/2-12	21.07.2025	Y
	Timer	K&A 581/1-12	14.07.2025	Y
X7 /X8	Scale	K&A 430-13	23.12.2025	Y
	Stop watch	K&A 1171-18	25.10.2025	Y

AXL Series of Aluminium Enclosures

Sr.No.	Dimension L X W X H in mm	Model Number
1	45 X 50 X 30	MM AXL B 01
2	64 X 58 X 34	MM AXL B 02
3	64 X 98 X 34	MM AXL B 03
4	80 X 75 X 57	MM AXL B 04
5	80 X 125 X 57	MM AXL B 05
6	80 X 175 X 57	MM AXL B 06
7	80 X 250 X 57	MM AXL B 07
8	100 X 100 X 81	MM AXL B 08
9	120 X 122 X 81	MM AXL B 09

Sr.No.	Dimension L X W X H in mm	Model Number
10	120 X 122 X 91	MM AXL B 10
11	140 X 140 X 91	MM AXL B 11
12	160 X 160 X 91	MM AXL B 12
13	180 X 180 X 101	MM AXL B 13
14	120 X 220 X 81	MM AXL B 14
15	120 X 220 X 91	MM AXL B 15
16	160 X 260 X 91	MM AXL B 16
17	230 X 400 X 181	MM AXL B 17



KARANDIKAR LABORATORIES PVT. LTD. BOISAR

Report No.: KLPL/BTG/25/01-123

Date: 17.05.2025

IS/IEC 60529:2001 (RA 2019)			
Clause	Requirement - Test	Result- Remark	Verdict
10	Marking.	--	N
11	General requirement for tests.		
11.1	Tests should be carried out under the standard atmospheric conditions described in IEC 60068-1	--	P
11.2	Test samples shall be in a clean and new condition.	--	P
	The relevant product standard shall specify details such as: The number of samples to be tested;	--	N
	-conditions for mounting, assembling and positioning of the samples;	--	P
	-the pre-conditioning, if any, which is to be used;	--	N
	-whether to be tested energized or not;	--	N
	-whether to be tested with its parts in motion or not;	--	N
11.5	Empty enclosures		
	If the enclosure is tested without equipment inside, the manufacturer shall ensure that after the electrical equipment is enclosed the enclosure meets the declared degree of Protection of the final product.	Empty enclosures	P

12	Tests for protection against access to hazardous parts indicated by the first characteristic numeral.				
First, characteristic Numeral.	Test means (Access probes)	Test force	Test Conditions Refer IS/IEC 60529:2001 (RA 2019)	--	
0	No test required	-	-	--	N
1	The access probe, sphere of 50 mm $\varnothing$ shall not fully penetrate and adequate clearance shall be kept.	50N $\pm 10\%$	Cl.12.2	--	N
2	The jointed test finger may penetrate up to 80 mm length but adequate clearance shall be kept.	30N $\pm 10\%$	Cl.12.2	--	N
3	The access probe, sphere of 2.5 mm $\varnothing$ shall not penetrate and adequate clearance shall be kept.	3N $\pm 10\%$	Cl.12.2	--	N
4	The access probe of 1,0 mm $\varnothing$ shall not penetrate and adequate clearance shall be kept.	1N $\pm 10\%$	Cl.12.2	--	N
5	Test conditions for IP 5X: Same As Above	1N $\pm 10\%$	Cl.12.2	--	N
6	Test conditions for IP 6X: Same As Above	1N $\pm 10\%$	Cl.12.2	--	N




Head Office: B-101, Ansa Industrial Estate, Saki Vihar Road, Saki Naka, Andheri (E) Mumbai-400072 INDIA Ph: (022) 28471395
Laboratory: Gat#142, Betegaon, Boisar Chilhar Road, Opp. Union Park, Boisar (E) Tal-Palghar, Dist Palghar-401501, INDIA Phone (02525) 284881/931

Email: sales@karandikarlab.com

Website: www.karandikarlab.com

IS/IEC 60529:2001 (RA 2019)					
Clause	Requirement – Test			Result-Remark	Verdict
13	Tests for protection against solid foreign objects indicated by the First characteristic numeral.				
First, characteristic Numeral.	Test means (object probes and dust chamber)	Test force	Test Conditions Refer IS/IEC 60529:2001 (RA 2019)	--	
0	No test required	-	-	--	N
1	Rigid sphere without handle or guard 50 mm diameter.	50N ±10%	Cl.13.2	--	N
2	Rigid sphere without or guard 12, 5 mm diameter.	30N ±10%	Cl.13.2	--	N
3	Rigid steel rod 2,5mm diameter with edges free from burrs	3N± 10%	Cl.13.2	--	N
4	Rigid steel wire 1, mm diameter with edges free from burrs.	1N± 10%	Cl.13.2	--	N
5	Dust chamber, with under pressure	NA	Cl.13.4+13.5	--	N
6	Dust chamber, The enclosure is maintained below the Surrounding atmospheric pressure by a vacuum pump.	NA	Cl.13.4+13.6	For 8 hrs. As extraction rate is less than 40 Volumes per hour and max depression of 20mbar.	P
13.6.2	Acceptance conditions for the first characteristic numeral 6X. The protection is satisfactory if no deposit of dust is observable inside the UUT at the end of test.			No ingress of dust found inside the UUT.	P



KARANDIKAR LABORATORIES PVT. LTD. BOISAR

Report No.: KLPL/BTG/25/01-123

Date: 17.05.2025

IS/IEC 60529:2001 (RA 2019)				
Clause	Requirement – Test		Result-Remark	Verdict
14	Tests for protection against water indicated by the second characteristic numeral.			
Second, characteristic Numeral.	Test means	Test Conditions Refer IS/IEC 60529:2001 (RA 2019)	--	
0	No test required	Cl.14.2.0	--	N
1	Drip box, Enclosure on turntable	Cl.14.2.1	--	N
2	Drip box, Enclosure in 4 fixed positions of 15 ° tilt	Cl.14.2.2	--	N
3	oscillating tube or spray nozzle, 60° from vertical	Cl.14.2.3	--	N
4	oscillating tube or spray nozzle, 180° from vertical	Cl.14.2.4	--	N
5	6.3-mm nozzle, tested with a spraying nozzle, distance 2.5 m to 3 m, water flow rate 12.5 l/min	Cl.14.2.5	--	N
6	12.5-mm nozzle, tested with a spraying nozzle, distance 2.5 m to 3 m, water flow rate 100 l/min	Cl.14.2.6	--	N
7	Immersion tank,	Cl.14.2.7	--	N
8	Immersion tank, Continuous immersion subject to agreement. Water temperature does not differ from that of equipment by more than 5K. Test Duration: 2Hrs.	Cl.14.2.8	The lowest point of UUT is located 1.5 meter below surface of water.	P
-	Acceptance conditions for IPX8: The protection is satisfactory if no water has accumulated near the insulation, cable end or entered cables or interferes with the correct operation of the equipment.	Cl.14.3	No ingress of water observed inside the UUT.	P
-	Tests for protection against access to hazardous parts indicated by the additional letter.	Cl.15	--	N

SUMMARY OF INGRESS PROTECTION TESTS ACCORDING TO IS/IEC 60529:2001 (RA 2019)

Conclusion of the IP68 test: PASS.

The results of the tests were in compliance with the requirements in the standard

IS/IEC 60529:2001 RA 2019 (RA 2019)


UUT=Unit Under Test




KARANDIKAR LABORATORIES PVT. LTD. BOISAR

Report No.: KLPL/BTG/25/01-123

Date: 17.05.2025



Picture 1: MM AXL Series of Aluminium Enclosure, Size: PI. Ref. Page No.02 of This Report



Picture2 : No ingress of dust & water observed

END OF REPORT



Table - A (Dimensions chart)

Models	Sizes	Dimensions			Wall Thickness		Mountings		Screw for Lid		
		A ±3	B ±3	C ±3	Base	Lid	D ±3	E ±3	Bolt	Size	Nos.
MM AXL B 04	80 x 75 x 57	80	75	57	3 Min.	2.5 Min.	52	63	M4x2 Nos.	M4x20L	4 Nos.
MM AXL B 05	80 x 125 x 57	80	125	57	3 Min.	2.5 Min.	52	113	M4x2 Nos.	M4x20L	4 Nos.
MM AXL B 06	80 x 175 x 57	80	175	57	3 Min.	2.5 Min.	52	163	M4x2 Nos.	M4x20L	4 Nos.
MM AXL B 07	80 x 250 x 57	80	250	57	3 Min.	2.5 Min.	52	238	M4x2 Nos.	M4x20L	4 Nos.
MM AXL B 08	100 x 100 x 81	100	100	81	3 Min.	3 Min.	66	86	M4x4 Nos.	M4x24L	4 Nos.
MM AXL B 09	120 x 122 x 81	120	122	81	4 Min.	4 Min.	82	106	M6x4 Nos.	M6x25L	4 Nos.
MM AXL B 10	120 x 122 x 91	120	122	91	4 Min.	4 Min.	82	106	M6x4 Nos.	M6x25L	4 Nos.
MM AXL B 11	140 x 140 x 91	140	140	91	4 Min.	4 Min.	93	120	M6x4 Nos.	M6x35L	4 Nos.
MM AXL B 12	160 x 160 x 91	160	160	91	4 Min.	4 Min.	110	140	M6x4 Nos.	M6x35L	4 Nos.
MM AXL B 13	180 x 180 x 101	180	180	101	4 Min.	4 Min.	130	160	M6x4 Nos.	M6x35L	4 Nos.
MM AXL B 14	120 x 220 x 81	120	220	81	4 Min.	4 Min.	82	204	M6x4 Nos.	M6x35L	4 Nos.
MM AXL B 15	120 x 220 x 91	120	220	91	4 Min.	4 Min.	82	204	M6x4 Nos.	M6x35L	4 Nos.
MM AXL B 16	160 x 260 x 91	160	260	91	4 Min.	4 Min.	110	240	M6x4 Nos.	M6x35L	4 Nos.
MM AXL B 17	230 x 400 x 181	230	400	181	4 Min.	5.2 Min.	180	380	M6x4 Nos.	M6x38L	4 Nos.

Notes:
THESE ALUMINIUM ENCLOSURES HAVE PASSED BELOW TESTS:


- THESE ALUMINIUM ENCLOSURES HAVE PASSED BELOW TESTS:
1. SALT SPRAY TEST: 1000 HOURS AS PER IS 9000 PART XI.
 2. IMPACT TEST: 7 JOULES (IS/IEC 60079-0, IEC 60079-0)
 3. IP TEST: IP 66 AND IP 68 (1.5 METERS, 2 HOURS) AS PER IS/IEC 60079:2001.

[illegible]

Maximum Nos. of Cable Entries on each side of enclosure

[illegible]

Maximum Nos. of Cable Entries on each side of enclosure

[illegible]



Detail "X" Tongue & Groove Arrangement



Refer Table A

Mfg. Year	Serial No.
A = 2024	000001
B = 2025	000002
C = 2026	000003
Z = 2050	999999

Self adhesive Name Plate Sticker



Report NO: KLPL/BTG/25/01-123

[illegible]

Annexure